






ift-Nachweis

Classification Report



Number	23-000386-PR02 (NW-A01-0203-en-01)
Owner	PIDOSAN A.S. Yuva Mah. 3702/1 Sokak No: 8 Ivedik O.S.B - Yenimahalle Ankara Türkiye
Product	Tilt and turn window with fixed sublight
Designation	System: INTERPEN SYSTEM 82MM Shipping name: WINDOW WITH FIXED LIGHT
Details	Manufacturer PIDOSAN A.S., Ankara; Material Polyvinylchloride unplasticized (PVC-U), with reinforcement; Type of opening Tilt and turn; Opening direction DIN left, inward opening; Overall dimensions (W x H) 1400 mm x 2100 mm
Special features	Test sequence. Position of locking. Increased operating forces.

Result **)

Air permeability according to EN 12207:2016-12	Resistance to wind load according to EN 12210:2016-03	Watertightness according to EN 12208:1999-11	Operating forces according to EN 13115:2020-08	Mechanical properties according to EN 13115:2020-08
				
4	C2/B2	8A	0	2

**) Decision rule: For the evaluation of conformity, the measurement uncertainty was not taken into account.

ift Rosenheim
19.07.2023



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Ioannis Sotiriadis, M.Eng.
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006+A2:2016-09

*) and corresponding national versions (e.g. DIN EN)

Test report: 23-000386-PR01 PB-A01-020305-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit. When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 895-79EAA